










MATERIALS & DESIGN DATA

NEXTROL:	CAST IRON, ASTM A126, CLASS B 175 PSIG, 250°F STANDARD 125# CLASS B FLANGES (MATES TO 150# FLANGES ALSO)
TWINTUBE PITOT:	316 STAINLESS STEEL TUBES, BRASS FITTINGS
NEXTUBE:	CAST IRON, ASTM A126, CLASS B, 175 PSIG, 250°F, STANDARD 125# CLASS B FLANGES (MATES TO 150# FLANGES ALSO)
BUTTERFLY VALVE:	EPOXY COATED CAST IRON, LUG TYPE BODY, ASTM A126, CLASS B, 225 PSIG, 250°F, EPDM SEAT, 304 STAINLESS STEEL DISK, 416 STAINLESS STEEL SHAFT, ON-OFF w/ HANDLE
BOLTS:	ZINC PLATED STEEL

ACCESSORIES

	Order Code	Part No.	Description
	<input type="checkbox"/> A	AV-025	AUTOMATIC AIR VENT 250°F, 150 PSIG, positive shut-off, ¼" MNPT
	<input type="checkbox"/> B	BD-050	BLOWDOWN / VENT / DRAIN 325°F, 600 PSIG, ¾" hose bib & cap
	<input type="checkbox"/> GB	BV-0600GB	GEARBOX WITH HAND WHEEL (for 6" thru 12")
	<input type="checkbox"/> H	HT	HANGING TAG with Model No., Location, Flow Rates (Maximum 7 Characters)
	<input type="checkbox"/> O	SV-025	SHUT-OFF VALVES 300°F, 600 PSIG, ¼" MNPT x ¼" FNPT
	<input type="checkbox"/> V	MV-025	MANUAL AIR VENT 325°F, 400 PSIG, ¼" MNPT, Side Discharge
	<input type="checkbox"/> W	TW-075	THERMOMETER WELL ¾" MNPT
	<input type="checkbox"/> X	MV-025L	MANUAL AIR VENT EXTENDED 325°F, 400 PSIG, ¼" MNPT, Side Discharge, 2¼" O.A.L.
		PTE	PRES / TEMP TEST PLUG EXTENSION 1⅞" O.A.L.

ORDER DATA

Sample Part #: **N 2 F N 0 2 5 0 - - - - - X**

Model	_____
Coil Pak Size	_____
<small>250=2½", 300=3", 400=4", 600=6", 800=8", 1000=10", 1200=12"</small>	
Extended Accessories (ES)	_____
Port Accessories (Return Side)	_____
Port Accessories (Supply Side)	_____
Option Order Codes (SV or HT)	_____
Option Order Codes (GB)	_____

N2FN coil paks include base model Nextrol & NexTube.
Additional accessories and options may be ordered separately.

PROJECT _____

CONTRACTOR _____

PO/JOB NO. _____

ENGINEER _____

REPRESENTATIVE _____

DATE _____